



CERTIFICATE OF APPROVAL

No CF 355

This is to certify that, in accordance with
TS00 General Requirements for Certification of Fire Protection Products
The undermentioned products of

PYROPLEX LIMITED

The Furlong, Droitwich, Worcestershire, WR9 9BG, United Kingdom

Tel: 01905 795432

Fax: 01905 795757

Web site: www.pyroplex.com

Have been assessed against the requirements of the Technical Schedule(s)
denoted below and are approved for use subject to the conditions
appended hereto:

CERTIFIED PRODUCT

Pyroplex intumescent seals
(with optional smoke and
acoustic control)

TECHNICAL SCHEDULE

TS35 – The Contribution Of
Intumescent Seals To The Fire
Resistance Of Pedestrian Type
Door Assemblies (Issue 2)

TS21 – The Contribution of Edge
Seals to the Control of Smoke
Leakage via Door Assemblies

Signed and sealed for and on behalf of Warringtonfire Testing and Certification Limited

Paul Duggan
Certification Manager

Issued: 2nd July 2004
Reissued: 28th February 2025
Valid to: 25th May 2025



CERTIFICATE No CF 355 PYROPLEX LIMITED

1. This certification is provided to the client for their own purposes and we cannot opine on whether it will be accepted by Building Control authorities or any other third parties for any purpose.







PYROPLEX INTUMESCENT DOOR EDGE SEALS – WITH OPTIONAL SMOKE AND ACOUSTIC CONTROL

1. This certificate of approval relates to the contribution of intumescent door edge seals to the fire resistance of pedestrian type door assemblies, for periods of 20/30 and 60 minutes fire, smoke resistance.

Pyroplex Rigid Box Seals

Pyroplex Rigid Box Seals comprise of a graphite based intumescent core encased within a PVC carrier. The seals are supplied with a high performance self adhesive strip in a range of cut lengths.

Pyroplex Rigid Box Seals are available as fire only systems, or with integral components for smoke and acoustic performance.


Dimension	 Fire Only (FO)	 Pile Only (PO)	 Pile with Fin (P+F)	 Single Flipper (SF)	 Twin Flipper (TF)	 Side Flipper (SDF)
10 x 4	8500	8512	8510	8524	8523	8923
15 x 4	8700	8712	8710	8724	8723	8924
20 x 4	8600	8612	8610	8624	8623	8925
25 x 4	8800	8812	8810			
30 x 4	30094	3009412	3009410			30218
38 x 4	30076	3007612	3007610			

Note: This approval applies to the described seals of nominal dimensions, but also includes seals of modified dimensions in all variations of finish, both with and without integral smoke seals. The table gives examples, however it is not absolute.

Pyroplex Rigid Box Seals can be supplied in a range of colours – Refer to Pyroplex Product Data Sheet.

EWC-QU-FT-733 (Issue 2)

Signed
CNI35686-1



Page 2 of 5

Issued: 2nd July 2004
Reissued: 28th February 2025
Valid to: 25th May 2025


CERTIFICATE No CF 355 PYROPLEX LIMITED

PYROPLEX INTUMESCENT DOOR EDGE SEALS – WITH OPTIONAL SMOKE AND ACOUSTIC CONTROL

Pyroplex Flexible Seals

Pyroplex Flexible Seals comprise of a graphite based intumescent core encapsulated in a polymer. The seals are supplied with a high performance self adhesive strip on continuous dispensing coils.

Pyroplex Flexible Seals are designed for fire only performance.


Dimension	
10 x 2.5	8979
10 x 3	30172
10 x 4	8989
15 x 2.5	8980
20 x 2.5	8981
20 x 4	30112
24 x 3.5	30171
25 x 2.5	8988
30 x 2.5	8986
40 x 2.5	8983

Note: This approval applies to the described seals of nominal dimensions, but also includes seals of modified dimensions in all variations of finish. The table gives examples, however it is not absolute.

Pyroplex Intumescent Strips

Pyroplex Intumescent Strips are graphite based intumescent seals. The seals are supplied with a high performance self adhesive strip on continuous dispensing coils.

Pyroplex Intumescent Strip is designed for fire only performance.

Dimension	
10 x 2.5	8492
15 x 2.5	8501
20 x 2	30074
20 x 2.5	8921
25 x 2	30142
30 x 2	30075
30 x 2.5	8958
40 x 2.5	8456

Note: This approval applies to the described seals of nominal dimensions, but also includes seals of modified dimensions in all variations of finish. The tables table gives examples, however they are not absolute.

EWC-QU-FT-733 (Issue 2)

Signed
CNI35686-1



Page 3 of 5

Issued: 2nd July 2004
Reissued: 28th February 2025
Valid to: 25th May 2025



CERTIFICATE No CF 355

PYROPLEX LIMITED

PYROPLEX INTUMESCENT DOOR EDGE SEALS – WITH OPTIONAL SMOKE AND ACOUSTIC CONTROL

2. The door seals are approved on the basis of:
 - i) A design appraisal against TS35 and TS21
 - ii) Initial type testing
 - iii) Manufacturing frequency checks
 - iv) Ageing and durability tests
 - v) Evidence of technical support
 - vi) Clear and unambiguous labeling of seals
 - vii) Certification to ISO9001: 2008
 - viii) Inspection and surveillance of factory production control
 - ix) Ongoing audit tests in accordance with TS35
3. The suitability of the seals in door assemblies not certificated by CERTIFIRE should be established by reference to the certification, test reports or assessments relating to the particular door assembly.
4. Pyroplex graphite based intumescent seals may be used with doorsets outside of the scope given above (paragraph 3) providing the door manufacturer's certification shows acceptability.
5. The approved Pyroplex seals shall have nominal widths and cross-sectional areas of intumescent at least equal to those in the tested/approved door assembly and shall be similarly positioned.
6. The approval additionally certifies that the described integral smoke seal variants are suitable for use with door assemblies required to restrict smoke leakage at ambient temperatures
7. The seals shall be installed in accordance with the manufacturer's instructions.
8. The approval relates to on going production. Product or its immediate packaging is identified with the manufacturers' name, the product name or number, the CERTIFIRE name or name and mark, together with the CERTIFIRE certificate number (i.e No. CF 355).
9. These seals are suitable to be used with:

CERTIFIRE approved FD30 single-acting, single leaf, latched or unlatched doorsets of maximum leaf dimensions 2040 mm high by 926 mm wide and of minimum thickness 42 mm. The doorset assemblies shall consist of timber faced and edged leaves with timber, cellulosic or mineral cores in timber frames (Code ITT). More information can be referred to in TS35. Pyroplex intumescent seals are suitable for use on FD60 doorsets- see Approval matrix on page 5 of 5.

EWC-QU-FT-733 (Issue 2)

Signed
CNI35686-1

Page 4 of 5

Issued: 2nd July 2004
Reissued: 28th February 2025
Valid to: 25th May 2025



CERTIFICATE No CF 355 PYROPLEX LIMITED

PYROPLEX INTUMESCENT DOOR EDGE SEALS – WITH OPTIONAL SMOKE AND ACOUSTIC CONTROL

The following specific CERTIFIRE approved doorsets:

Certificate	FD	Max. Height (mm)	Max. Width (mm)	Max. Area (m ²)	Configurations	Minimum Pyroplex Seal Size (mm)
CF385	FD30	2472	982	2.00	SASL	1 off 10 x 4 positioned centrally
CF492						1 off 15 x 4 positioned centrally
CF466		2195	956	2.04		1 off 15 x 4 positioned centrally
CF385	FD30	2512	1047	2.51	SADL	2 off 10 x 4 separated by 10 mm around the centre line
CF492						1 off 15 x 4 positioned centrally (2 off 10 x 4 separated by 10 mm at meeting edges)
CF466		2684	1006	2.45		1 off 15 x 4 positioned centrally (2 off 10 x 4 separated by 10 mm at meeting edges)
CF403	FD60	2040	826	1.68	SASL	2 off 15 x 4 separated by 10 mm around the centre line
CF575						
CF467		2135	932	1.99	SASL & SADL	

Note: Maximum permitted values at dimensions greater than specified may be determined graphically by linear interpolation between the two data points for each configuration. Under no circumstances must either the maximum height, maximum width or maximum area be exceeded or the configuration

EWC-QU-FT-733 (Issue 2)

Signed

CNI35686-1

Page 5 of 5

Issued: 2nd July 2004

Reissued: 28th February 2025

Valid to: 25th May 2025