



CERTIFICATE OF APPROVAL

No CF 5839

This is to certify that, in accordance with
TS00 General Requirements for Certification of Fire Protection Products
The undermentioned products of

FIRE & ACOUSTIC SEALS LTD

**Unit 6-11 Spartan Industrial Centre
Brickhouse Lane
West Bromwich
West Midlands
B70 0DH
TEL: 0121 521 2179**

Have been assessed against the requirements of the Technical Schedule(s)
denoted below and are approved for use subject to the conditions
appended hereto:

CERTIFIED PRODUCT

**Fire & Acoustic Seals Ltd 'Fire
Door Foam'**

TECHNICAL SCHEDULE

**TS40 Linear Gap Sealing
Systems**

Signed and sealed for and on behalf of Warringtonfire Testing and Certification Limited

**Paul Duggan
Certification Manager**



Issued: 19th June 2020
Reissued: 19th September 2025
Valid to: 18th December 2025





CERTIFICATE No CF 5839

FIRE & ACOUSTIC SEALS LTD

Fire & Acoustic Seals Ltd 'Fire Door Foam'

1. This approval relates to the use of Fire & Acoustic Seals Ltd 'Fire Door Foam' for the fire protection of joints between walls and timber based door frames. The detailed scope is given in the Approval Matrix included in this Certificate. This shows the thickness and acceptable capping configurations types required to provide fire resistance periods in accordance with BS 476: Part 22. The scope of certification complies with the guidelines stated in the ASFP Red Book: 3rd Edition for 3rd party certification schemes.
2. This certification is provided to the client for their own purposes and we cannot opine on whether it will be accepted by Building Control authorities or any other third parties for any purpose.
3. This product is approved on the basis of:
 - i) Initial type testing
 - ii) Audit testing at the frequency specified in TS40
 - iii) A design appraisal against TS40
 - iv) Inspection and surveillance of factory production control
4. Flexible wall types constructed from timber or steel stud shall be framed out and have a minimum thickness of 78 mm for 30 minute applications, 119 mm for 60 minute applications and 130 mm for 90 & 120 minute Fire Resistance applications.
5. The approval relates to ongoing production. Product and/or its immediate packaging is identified with the manufacturers' name, the product name or number, the CERTIFIRE name or name and mark, together with the CERTIFIRE certificate number and application where appropriate.

Further information regarding the details contained in this data sheet may be obtained from FIRE & ACOUSTIC SEALS (Tel: 0121 521 2179).

Further information regarding the CERTIFIRE certification and other approved products can be obtained from CERTIFIRE (Tel: 01925 646777).

Signed Page 2 of 4
E/043

Issued: 19th June 2020
Reissued: 19th September 2025
Valid to: 18th December 2025



CERTIFICATE No CF 5839

FIRE & ACOUSTIC SEALS LTD

Fire & Acoustic Seals Ltd 'Fire Door Foam' - Approval Matrix

Wall Installations min.78 mm Thick with FD30 doorsets (architraves optional)					
Wall type	Door frame substrate	Minimum seal depth	Maximum joint width	Mastic capping requirement	Integrity (mins)
Masonry	Softwood	78 mm	30 mm	No	30
Plasterboard faced timber stud wall	Softwood				30
Plasterboard faced steel stud wall	Softwood				30
Masonry	MDF				30
Plasterboard faced timber stud wall	MDF				30
Plasterboard faced steel stud wall	MDF				30
Masonry	Hardwood				30
Plasterboard faced timber stud wall	Hardwood				30
Plasterboard faced steel stud wall	Hardwood				30
Application Technique	For good adhesion the surfaces of the building element shall be free of any dust or grease and be suitably primed.				

Wall Installations min.119 mm Thick with FD60 doorsets (architraves optional)					
Wall type	Door frame substrate	Minimum seal depth	Maximum joint width	Mastic capping requirement	Integrity (mins)
Masonry	Hardwood	112 mm	25 mm	No	60
Plasterboard faced timber stud wall	Hardwood				60
Plasterboard faced steel stud wall	Hardwood				60
Application Technique	For good adhesion the surfaces of the building element shall be free of any dust or grease and be suitably primed.				

Signed Page 3 of 4
E/043

Issued: 19th June 2020
Reissued: 19th September 2025
Valid to: 18th December 2025



CERTIFICATE No CF 5839

FIRE & ACOUSTIC SEALS LTD

Wall Installations min.130 mm Thick with FD90 doorsets (architraves optional)					
Wall type	Door frame substrate	Minimum seal depth	Maximum joint width	Mastic capping requirement	Integrity (mins)
Masonry	Hardwood	112 mm	25 mm	10 mm Fire & Acoustic Seals Ltd Intumescent Acrylic Sealant applied to each face	90
Plasterboard faced timber stud wall	Hardwood				90
Plasterboard faced steel stud wall	Hardwood				90
Application Technique	For good adhesion the surfaces of the building element shall be free of any dust or grease and be suitably primed.				

Wall Installations min.130 mm Thick with FD120 doorsets (architraves optional)					
Wall type	Door frame substrate	Minimum seal depth	Maximum joint width	Mastic capping requirement	Integrity (mins)
Masonry	Hardwood	112 mm	25 mm	10 mm Fire & Acoustic Seals Intumescent Acrylic Sealant applied to each face	120
Timber Stud	Hardwood				120
Steel Stud	Hardwood				120
Application Technique	For good adhesion the surfaces of the building element shall be free of any dust or grease and be suitably primed.				

Signed Page 4 of 4
E/043

Issued: 19th June 2020
Reissued: 19th September 2025
Valid to: 18th December 2025