INTERNATIONAL FIRE CONSULTANTS LIMITED

Ref: Fireprotect120514/#13374

12 May 2014

By email only: fireprotectchester@yahoo.co.uk

Mrs N Baker
Fireprotect (Chester) Ltd
Factory Road
Sandycroft
Deeside
Flintshire
CH5 2QJ

Dear Niky,

PAR/13374/01
Letter of Opinion relating to Fireprotect Glazing Tape

I am writing in response to your request for confirmation that the 'heat transfer' through a ceramic fibre tape (which includes non-body soluble fibres) is comparable to the Fireprotect tape (which includes body soluble fibres), when subjected to an elevated temperature.

International Fire Consultants Ltd. (IFC) have completed some initial testing whereby the Fireprotect glazing tape and a control ceramic fibre tape product were subjected to a 200°C hotplate and the temperature on the unexposed face was recorded with thermocouples. The results were comparable within experimental error.

Should you, or any of the parties involved, require any further information regarding this Letter of Opinion, please feel free to contact me.

Prepared by:



Dr Parina Patel
BSc (Hons) PhD MIFireE
Fire Safety Engineer
International Fire Consultants Ltd. (IFC)

Checked by:



David Cooper
BEng (Hons) AIMMM
Senior Fire Safety Engineer
International Fire Consultants Ltd.